

KENYA MEDICAL SUPPLIES AUTHORITY

National Supply Chain Centre,
Airport North Road, Embakasi,
P.O. Box 47715 - 00100,
Nairobi, Kenya.



Tel: +254 719 033000, +254 111 035 800
Email: info@kemsas.go.ke

All Correspondence should be addressed to Chief Executive Officer

When replying please quote our ref:

KEMSA/GF-PROC/TB GC7/OIT 5,6&7/2025

Date: 19th March, 2025

CLARIFICATION 1

ATTN.: ALL PROSPECTIVE BIDDERS

TENDER NOs.:

1. GF ATM TB C19RM 2024-2025 OIT 05- PROCUREMENT OF SPECIALIZED WORKS- FOR COLD ROOM FLOOR (EPOXY)
2. GF ATM TB C19RM 2024-2025 OIT 06- SUPPLY OF COLD ROOM RACKS
3. GF ATM TB C19RM 2024-2025 OIT 07- SUPPLY OF DOCK DOORS

In accordance with ITT Clause 7.1 (Clarification of Tendering Document) of the Open International Tender (OIT) issued under the above reference, were hereby respond to query raised by one prospective bidder:

Question 1;

Will another tender document be uploaded without the errors as discussed during the pre tender conference or we will have to fill the tender document as it is?

Response: There is no other document to be uploaded. Fill as is, taking to account all the clarification shared.

Question 2;

On Bill of Qualities, what does Preliminaries Entail?

Response: Any associated cost which the bidder may incur to ensure successful delivery of the project e.g. Insurances, performance bonds, security etc.

Question 3;

Clarification is sought on

SECTION III - EVALUATION AND QUALIFICATION CRITERIA, APPENDIX TO SECTION III MANDATORY EVALUATION MR 10, MR 11 and MR 12 require certified

[Handwritten signature]

trainer by the Director of Occupational Safety and Health Services in Occupation Health and Safety, Fire Safety and First Aid Providers respectively.

Response; the clarification required is not clear

Question 4;

TECHNICAL EVALUATION

Qualification and Experience of KEY Personnel indicates we are to provide Academic Qualifications and Experience for a trainer in Occupation Health and Safety and First Aid Providers respectively, registered under the Company or collaborating companies.

We therefore seek clarification on the following:

- a) Is the bidding company supposed to be a trainer registered and approved as an occupational safety and health training institutions under the ministry of labour and social protection?

Response; there supposed to have staff who is trained as a trainer and certification need to be attached. This is the person who will train the staff working on site.

Question 4(b);

As an option, is the bidding company supposed to be collaborating with an approved as an occupational safety and health training institutions under the ministry of labour and social protection?

Response; this is acceptable on condition there is a binding agreement or contract which evidence must be provided.

Question 4(c);

Further to this, are we to attach CVS of approved staff trained under these approved organization?

Response; yes

Question 4(d);

Looking at the scope of works and the BoQ, the works are typically civil works, with no provision for training on OSHA and thus no relevance of having an approved trainer but rather in having trained personnel to oversee safety and health aspects of the works. From the above, could we just attach the CVS of personnel trained by approved trainer institutions, who in some instances are consultants who can work in different organizations.

Response; see (b) above

Question 5;

After review of the proposed support structure for the cold rooms
i.e 'Plate reinforcing the floor 5mm Aluminum checker plate with Zero but welded
joints dowelled to panel below and firmly secured with wall to receive the Polyurethane
resin'- Item 4 in the BQ.

Our technical opinion is that it shall not work and guarantee the 10 warranties of the
works. In our considered technical opinion, the floor needs to be redone as follows


- remove the currently installed flooring and redo as follows;
- polystyrene foam 75mm thick.
- Concrete flooring screed with 210mm thick. Class C25.

Reinforced rebar can be either: -

- D8 rebars with 150mm wide space.
- D10 rebar with 200mm wide space.

Response; Not possible, Quote as is

Yours faithfully,



Moses Sudi
Procurement Director
FOR: CHIEF EXECUTIVE OFFICER

